

STORMWATER POST-CONSTRUCTION TREATMENT DEVICE OPERATIONS & MAINTENANCE

Fire Station # 36
855 North Deerhill Rd, Oak Park

Devices On-Site:
Drywell

Sedimentation Manhole



Observation Well



Operations & Maintenance Plan

Date: _____ O & M Personnel: _____ Signature: _____

O & M Frequency:

Pre-Wet Season
(before Oct 1)

Post-Wet Season
(after April 15)

After Storm

Drywell			
Activity	O & M Needed	O & M Completed	Comments / Maintenance Performed
Open Manhole and Remove Trash/Debris/Sediments.			
Repair Clear Blockages of Inlet/Outlet Pipe			
If standing water is present in observation well 4 days after rain event, maintenance is needed immediately to restore infiltration. (This may require removal and replacement of topsoil, gravel/aggregate layers, and filter fabrics)			