

STORMWATER POST-CONSTRUCTION TREATMENT DEVICE OPERATIONS & MAINTENANCE

Fire Station # 52
5353 Santa Rosa Rd, Camarillo

Devices On-Site:
Drywell



Operations & Maintenance Plan

Date: _____

O & M Personnel: _____

Signature: _____

O & M Frequency: Pre-Wet Season (before Oct 1) Post-Wet Season (after April 15) After Storm

Drywell			
Activity	O & M Needed	O & M Completed	Comments / Maintenance Performed
Open Manhole and Remove Trash/Debris/Sediments.			
Repair Clear Blockages of Inlet/Outlet Pipe			
If standing water is present in observation well 4 days after rain event, maintenance is needed immediately to restore infiltration. (This may require removal and replacement of topsoil, gravel/aggregate layers, and filter fabrics)			