

# STORMWATER POST-CONSTRUCTION TREATMENT DEVICE OPERATIONS & MAINTENANCE

**Fire Station # 57**  
**3356 Somis Rd, Somis**

Devices On-Site:  
Drywell

Observation  
Well



Sedimentation  
Manhole



# Operations & Maintenance Plan

Date: \_\_\_\_\_ O & M Personnel: \_\_\_\_\_ Signature: \_\_\_\_\_

O & M Frequency:     Pre-Wet Season (before Oct 1)     Post-Wet Season (after April 15)     After Storm

Drywell			
Activity	O & M Needed	O & M Completed	Comments / Maintenance Performed
Open Manhole and Remove Trash/Debris/Sediments.			
Repair Clear Blockages of Inlet/Outlet Pipe			
If standing water is present in observation well 4 days after rain event, maintenance is needed immediately to restore infiltration. (This may require removal and replacement of topsoil, gravel/aggregate layers, and filter fabrics)			