STORMWATER POST-CONSTRUCTION TREATMENT DEVICE OPERATIONS & MAINTENANCE

Ventura County Probation Agency 4333 Vineyard Ave, Oxnard

Devices On-Site: Infiltration Basin



Operations & Maintenance Plan

Date:	O & M Pers	sonnel:		Signature:
0 & M		Pre-Wet Season Post-Wet Seaso (before Oct 1) (after April 1		
Γ	Infiltration Basin			
	Activity	O & M Needed	O & M Completed	Comments / Maintenance Performed
	Remove Trash / Debris/Sediment			
	Assess for Poor Vegetative Health (i.e. Weeds, grass > 6" tall, loss of ground cover)			
	Remove Weeds			
	Repair Erosion/Scouring			
	If Standing Water is present 4 days after rain event, maintenance is needed immediately to restore infiltration. (See O & M details in 2011 Technical Guidance Manual Chapter 6 Page 22)			

*2011 Technical Guidance Manual is available under Publications/Manuals @ http://vcstormwater.org