



NOTES:

1. END GRATE TO FIT INSIDE FLANGE OF TRASH RACK.
2. GALVANIZE ALL STEEL PARTS AFTER FABRICATION PER 210-3.1 OF SPPWC.
3. FOR DAMAGED ZINC COATING PARTS SEE SECTION PER 210-3.5 OF SPPWC
4. EXPOSED EDGES OF CONCRETE MEMBERS SHALL BE CHAMFERED 3/4" X 3/4".
5. THE CONTRACTOR SHALL FIELD MEASURE THE WIDTH & THE LENGTH OF ALL FOUR SIDES OF THE CONCRETE INTAKE STRUCTURE'S CREST, ANY DISCREPANCIES SHALL BE REPORTED TO THE ENGINEER PRIOR TO THE MANUFACTURING OF TRASH RACK.
6. CONSTRUCT RC TOWER PER STRUCTURAL DETAILS, SEE SHEETS -----.
7. DEPTH OF THE SUBGRADE STABILIZER MATERIAL SHALL BE IN COMPLIANCE WITH THE GEOTECHNICAL REPORT.

REVISION	DESCRIPTION	APP.	DATE
D			
C			
B			
A			

DESIGNED	WATERSHED PROJECT MANAGER	DATE
DRAWN	WATERSHED DEPUTY DIRECTOR	DATE
CHECKED	WATERSHED DIRECTOR	DATE

**VENTURA COUNTY
PUBLIC WORKS AGENCY
WATERSHED PROTECTION**

SPEC. NO. WP-	PROJECT NAME RC INTAKE STRUCTURE DETAILS	SHEET
PROJ. NO.		OF
		DRAWING NO. WP-??-??